


Safety Net Test Report


Date 15 July 2013
Reference No 05054-SNT-003
Client Motueka Nets
Tested by Lance Hope MIPENZ(Industrial, Mechanical) CPEng IntPE
Test Location Motueka Nets 265 Akersten Street Nelson
Photos ref Net Testing 2013 6 14/ Nylon 6x6-3x3 / Nylon 6x6-2x2

Description of Test 2m Drop Test with 100kg Dummy

Plate height	2400mm	Net	Nylon
Hanger centres	800mm	Chord Dia	2.5 mm
Frame size	6x6m	Mesh	100mm
Bracing	Y=2400, X=3400	Dummy attitude	semi prone



PLAN VIEW



SIDE VIEW

Test Results

Position	Drop Point m		Height to ctr mm		Comments
	Dist wall 1	Dist wall 2	Start	Finish	
1	2	2	2270	1300	
2	3	3	2280	1200	
3					

DROP TEST RESULT

Passed

Signed *L K Hope*

Date of test

10 June 2013